

Omara OM-A6 Environment Monitoring System

Enquiry 1 @ Small setup network room:

Requirement:

1. Standalone device with monitoring input point for:
 - a. Temperature / humidity sensor
 - b. DI – fire alarm panel common alarm
 - c. DI – A/C changeover board common alarm (NO/NC)
 - d. DI – Electrical distribution board common alarm (NO/NC)
 - e. DI – UPS common alarm x 2 nos. (NO/NC)
 - f. DI – Water Leak System x 1 no.
2. SMS Alarm alert.

3. New Monitoring Point (Requirement)

| Point | System / Equipment | Description | Input Sensor type | Input type |
|-------|--------------------|----------------------------|-------------------|-----------------|
| 1. | Room temp/humidity | Omara Temp/Hum Server Room | Temp/hum sensor | |
| 2. | Fire System | Fire Alarm Panel | Common alarm | NO/NC |
| 3. | Electrical System | Air-con Changeover Board | Common alarm | NO/NC |
| 4. | Electrical System | Electrical Main DB | Common alarm | NO/NC |
| 5. | UPS System | UPS no.1 | UPS Common alarm | NO/NC or RS485 |
| 6. | UPS System | UPS no.2 | UPS Common alarm | NO/NC or RS485 |
| 7. | Water Leak System | Omara WDS System | Common alarm | NO/NC or RS 485 |

Enquiry 2 @ Westport Malaysia

Requirement:

1. Electrical system – RS485
2. A/C System (Precision cooling system x 3 units + FCU unit x 2 units)
3. Electrical supply for port tower x (qty to be justify further by coming week site visit)
4. Alarm alert: SMS and email
5. Web-enable solution

** proposed to replace existing GE Monitoring system (attached some related photo for your reference for time being.)

Existing Monitoring System @ Westport Data Center

System: GE Environmental Monitoring System

(1) Monitoring Point from existitng GE System

| Point | System / Equipment | Description | Input Sensor type | Input type |
|-------|-----------------------------|--------------------------------|-------------------------------|----------------|
| 1. | Cooling System | Precision cooling unit no.1 | via cooling system controller | RS 485 |
| 2. | Cooling System | Precision cooling unit no.2 | | RS 485 |
| 3. | Cooling System | Precision cooling unit no.3 | | RS 485 |
| 4. | Electrical System | AC-SB-1 | Via power metering EPM 5500P | RS 485 |
| 5. | Electrical System | AC-SB-2 | | RS 485 |
| 6. | Electrical System | PDU-1 | | RS 485 |
| 7. | Electrical System | PDU-2 | | RS 485 |
| 8. | UPS System | UPS-1 | Via UPS system controller | RS 485 |
| 9. | UPS System | UPS-2 | | RS 485 |
| 10. | Room temp/humidity | Temp/Hum Server Room 1 | Temp/hum sensor | |
| 11. | Room temp/humidity | Temp/Hum Server Room 2 | Temp/hum sensor | |
| 12. | Room temp/humidity | Temp/Hum Network Room | Temp/hum sensor | |
| 13. | Room temp/humidity | Temp/Hum Staging /Console Room | Temp/hum sensor | |
| 14. | Room temp/humidity | Temp/Hum M&E Room | Temp/hum sensor | |
| 15. | Smoke Detection System | HSSD-1 | HSSD controller | NO/NC |
| 16. | Smoke Detection System | HSSD-2 | HSSD controller | NO/NC |
| 17. | Smoke Detection System | HSSD-3 | HSSD controller | NO/NC |
| 18. | Water Leak Detection System | TTK-FG-SYS | WDS controller | NO/NC or RS485 |
| 19. | Fire Protection System | Fire Panel Common Alarm | Fire control panel | NO/NC |
| 20. | Fire Protection System | 1 st Fire Alarm | Fire control panel | NO/NC |
| 21. | Fire Protection System | 2 nd Fire Alarm | Fire control panel | NO/NC |

| | | | | |
|-----|--------------------------------------------------|-------------------|------------------------------|--------|
| 22. | Electrical System | PCU-LV-4 | Via power metering EPM 5500P | RS-485 |
| 23. | UPS System | UPS-3 LV-4 | Via UPS system controller | RS 485 |
| 24. | Room temp/humidity | Level 4 Room | Temp/hum sensor | |
| 25. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 1-1 | Temp sensor | |
| 26. | | | Electrical Power Fail | |
| 27. | | | UPS Alarm | |
| 28. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 1-2 | Temp sensor | |
| 29. | | | Electrical Power Fail | |
| 30. | | | UPS Alarm | |
| 31. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 2-1 | Temp sensor | |
| 32. | | | Electrical Power Fail | |
| 33. | | | UPS Alarm | |
| 34. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 2-2 | Temp sensor | |
| 35. | | | Electrical Power Fail | |
| 36. | | | UPS Alarm | |
| 37. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 3-1 | Temp sensor | |
| 38. | | | Electrical Power Fail | |
| 39. | | | UPS Alarm | |
| 40. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 3-2 | Temp sensor | |
| 41. | | | Electrical Power Fail | |
| 42. | | | UPS Alarm | |
| 43. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 4-1 | Temp sensor | |
| 44. | | | Electrical Power Fail | |
| 45. | | | UPS Alarm | |
| 46. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 4-2 | Temp sensor | |
| 47. | | | Electrical Power Fail | |
| 48. | | | UPS Alarm | |
| 49. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 4-3 | Temp sensor | |
| 50. | | | Electrical Power Fail | |
| 51. | | | UPS Alarm | |
| 52. | | Comm Tower CT 5-1 | Temp sensor | |

| | | | | |
|-----|--------------------------------------------------|-------------------|-----------------------|--|
| 53. | Room Temperature / Electrical Board / UPS System | | Electrical Power Fail | |
| 54. | | | UPS Alarm | |
| 55. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 5-2 | Temp sensor | |
| 56. | | | Electrical Power Fail | |
| 57. | | | UPS Alarm | |
| 58. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 6-1 | Temp sensor | |
| 59. | | | Electrical Power Fail | |
| 60. | | | UPS Alarm | |
| 61. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 6-2 | Temp sensor | |
| 62. | | | Electrical Power Fail | |
| 63. | | | UPS Alarm | |
| 64. | Room Temperature / Electrical Board | Comm Tower TB-1 | Temp sensor | |
| 65. | | | Electrical Power Fail | |
| 66. | Room Temperature / Electrical Board | Comm Tower TB-2 | Temp sensor | |
| 67. | | | Electrical Power Fail | |
| 68. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 7-1 | Temp sensor | |
| 69. | | | Electrical Power Fail | |
| 70. | | | UPS Alarm | |
| 71. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 7-2 | Temp sensor | |
| 72. | | | Electrical Power Fail | |
| 73. | | | UPS Alarm | |
| 74. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 8-1 | Temp sensor | |
| 75. | | | Electrical Power Fail | |
| 76. | | | UPS Alarm | |
| 77. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 8-2 | Temp sensor | |

| | | | | |
|-----|--------------------------------------------------|-------------------|-----------------------|--|
| 78. | | | Electrical Power Fail | |
| 79. | | | UPS Alarm | |
| 80. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 9-1 | Temp sensor | |
| 81. | | | Electrical Power Fail | |
| 82. | | | UPS Alarm | |
| 83. | Room Temperature / Electrical Board / UPS System | Comm Tower CT 9-2 | Temp sensor | |
| 84. | | | Electrical Power Fail | |
| 85. | | | UPS Alarm | |

(2) Additional Monitoring Point (to be add to new Omara System)

| Point | System / Equipment | Description | Input Sensor type | Input type |
|-------|--------------------|-------------------------------|---------------------------|------------|
| 1. | UPS battery bank | Individual battery monitoring | Battery Monitoring system | |
| | | | | |
| | | | | |

** Existing UPS battery monitoring system used B-Tech (USA) product.

** UPS Battery Bank details

- (A) 2 nos. of GE 200kVA UPS: 12V 200Ah SLA battery @ 32 nos. x 2 bank
- (B) 1 no of GE 60kVA UPS: 12V 100Ah SLA battery @ 32 nos.

Attachement:



Photo 1& 2: EPM 5500P Power Metering System, generate RS 485 input for AC-SB 1 and AC-SB 2.






Photo 3& 4: User existing UPS battery monitoring system (Brand: BTech SCM-600)



Existing GE Monitoring System: Page 1 view

Data Centre Monitoring System

Level 4



Existing GE Monitoring System: Page 2 view

Data Centre Monitoring System



CT1-1 CT1-2 CT4-1 CT4-2

| | | | |
|---------------------|---------------------|---------------------|---------------------|
| 33.1 °C Temperature | 30.8 °C Temperature | 28.9 °C Temperature | 32.7 °C Temperature |
| | | | |
| | | | |

CT2-1 CT2-2 CT4-3 CT5-1

| | | | |
|---------------------|---------------------|---------------------|---------------------|
| 24.3 °C Temperature | 28.9 °C Temperature | 00.0 °C Temperature | 32.9 °C Temperature |
| | | | |
| | | | |

CT3-1 CT3-2 CT5-2 CT6-1

| | | | |
|---------------------|---------------------|---------------------|---------------------|
| 24.5 °C Temperature | 34.0 °C Temperature | 00.0 °C Temperature | 33.4 °C Temperature |
| | | | |
| | | | |

TB-1 TB-2 CT6-2

| | | |
|---------------------|---------------------|---------------------|
| 36.5 °C Temperature | 00.0 °C Temperature | 33.6 °C Temperature |
| | | |

CT7 Alarm

Exit Main Level 4 Back Message

Date Time Project Name Ack Alarm ID State Message

| Date | Time | Project Name | Ack | Alarm ID | State | Message |
|-----------------|-------|--------------|-----|---------------------|--------|----------------------------------------------------------------------------------|
| Jan 30 | 11:30 | WESTPORTS | N | DB_CONN_DOWN | ALARM | The process CV4dB has lost its database connection to SQL Server Native Client 1 |
| Jan 25 | 23:45 | WESTPORTS | N | PEC_3_ALM_AIRFLOW | NORMAL | PEC 3 - Airflow Nam PEC 3 ALM AIRFLOW |
| Jan 19 | 11:36 | WESTPORTS | N | EASYO-CT4-2-UPS_GEN | NORMAL | CT4-2 - UPS General Alarm |
| Jan 19 | 10:49 | WESTPORTS | N | EASYO-CT4-1-UPS_GEN | NORMAL | CT4-1 - UPS General Alarm |
| Jan 19 | 10:03 | WESTPORTS | N | EASYO-CT4-1-PWRFAIL | NORMAL | CT4-1 Power Failure Alarm |
| Jan 19 | 08:53 | WESTPORTS | N | EASYO-CT4-2-COM_ERR | NORMAL | CT4-2 Communication Error Alarm |
| Jan 19 | 08:44 | WESTPORTS | N | EASYO-CT4-2-PWRFAIL | NORMAL | CT4-2 Power Failure Alarm |
| 26 Jan 30 11:30 | | | | | | |

Existing GE Monitoring System: Page 3 view

Data Centre Monitoring System



| CT7-1 |
|-------------------------|
| 35.5 °C Temperature |
| Power Fail UPS Alarm |

| CT7-2 |
|-------------------------|
| 29.1 °C Temperature |
| Power Fail UPS Alarm |

| CT8-1 |
|-------------------------|
| 30.6 °C Temperature |
| Power Fail UPS Alarm |

| CT8-2 |
|-------------------------|
| 29.2 °C Temperature |
| Power Fail UPS Alarm |

| CT9-1 |
|-------------------------|
| 29.6 °C Temperature |
| Power Fail UPS Alarm |

| CT9-2 |
|-------------------------|
| 29.9 °C Temperature |
| Power Fail UPS Alarm |

| CT1-6 | | | | | | |
|--------|-------|--------------|---------|---------------------|--------|----------------------------------------------------------------------------------|
| | Exit | Main | Level 4 | Back | Alarm | |
| Date | Time | Project Name | Ack | Alarm ID | State | Message |
| Jan 30 | 11:30 | WESTPORTS | N | DB_CONN_DOWN | ALARM | The process CV4d8 has lost its database connection to SQL Server Native Client 1 |
| Jan 25 | 23:45 | WESTPORTS | N | PEC_3_ALM_AIRFLOW | NORMAL | PEC_3 -AirFlow Alarm PEC_3_ALM_AIRFLOW |
| Jan 19 | 11:36 | WESTPORTS | N | EASYIO-CT4-2UPS_GEN | NORMAL | CT4-2 -UPS General Alarm |
| Jan 19 | 10:49 | WESTPORTS | N | EASYIO-CT4-1UPS_GEN | NORMAL | CT4-1 -UPS General Alarm |
| Jan 19 | 10:03 | WESTPORTS | N | EASYIO-CT4-1PWRFAIL | NORMAL | CT4-1Power Failure Alarm |
| Jan 19 | 08:53 | WESTPORTS | N | EASYIO-CT4-2COM_ERR | NORMAL | CT4-2 Communication Error Alarm |
| Jan 19 | 08:44 | WESTPORTS | N | EASYIO-CT4-2PWRFAIL | NORMAL | CT4-2 Power Failure Alarm |

Existing GE Monitoring System: Page 4 view

Data Centre Monitoring System



| Date | Time | Project Name | Ack | Alarm ID | State | Message |
|--------|-------|--------------|-----|----------------------|--------|----------------------------------------------------------------------------------|
| Jan 30 | 11:30 | WESTPORTS | N | DB_CONN_DOWN | ALARM | The process CV4d8 has lost its database connection to SQL Server Native Client 1 |
| Jan 25 | 23:45 | WESTPORTS | N | PEC_3.ALM_AIRFLOW | NORMAL | PEC_3 - Air Flow Alarm PEC_3.ALM_AIRFLOW |
| Jan 19 | 11:36 | WESTPORTS | N | EASYIO-C.T4-2.UPS... | NORMAL | CT 4-2 - UPS General Alarm |
| Jan 19 | 10:49 | WESTPORTS | N | EASYIO-C.T4-1.UPS... | NORMAL | CT 4-1 - UPS General Alarm |
| Jan 19 | 10:03 | WESTPORTS | N | EASYIO-C.T4-1.PWRF. | NORMAL | CT4-1 Power Failure Alarm |
| Jan 19 | 08:53 | WESTPORTS | N | EASYIO-C.T4-2.COM... | NORMAL | CT4-2 Communication Error Alarm |
| Jan 19 | 08:44 | WESTPORTS | N | EASYIO-C.T4-2.PWRF. | NORMAL | CT4-2 Power Failure Alarm |
| Jan 15 | 01:20 | WESTPORTS | N | EASYIO-C.T5-2.COM... | ALARM | CT5-2 Communication Error Alarm |
| Jan 09 | 12:37 | WESTPORTS | N | EASYIO-C.T4-3.COM... | ALARM | CT4-3 Communication Error Alarm |
| Jan 09 | 11:25 | WESTPORTS | N | PEC_1.ALM_HIPRES2 | NORMAL | PEC_1 System 2 High Pressure Alarm PEC_1.ALM_HIPRES2 |
| Jan 09 | 11:24 | WESTPORTS | N | PEC_2.ALM_RMPRES | NORMAL | PEC_2 - Room Pressure Probe Fault Or Disconnected Alarm PEC_2.ALM_RMPRES |
| Jan 09 | 11:24 | WESTPORTS | N | PEC_2.ALM_HIHUMID | NORMAL | PEC_2 - Humidity High Alarm PEC_2.ALM_HIHUMID |
| Jan 09 | 11:24 | WESTPORTS | N | PEC_2.ALM_SUPPAIR | NORMAL | PEC_2 - Supply Air Probe Fault or Disconnected Alarm PEC_2.ALM_SUPPAIR |
| Jan 09 | 11:24 | WESTPORTS | N | PEC_2.ALM_HIPRES2 | NORMAL | PEC_2 System 2 High Pressure Alarm PEC_2.ALM_HIPRES2 |
| Jan 09 | 11:23 | WESTPORTS | N | PEC_2.ALM_HIRMTE | NORMAL | PEC_2 - Room Temperature High Alarm PEC_2.ALM_HIRMTEMP |
| Jan 09 | 09:04 | WESTPORTS | N | EASYIO-1.TEMP1 | NORMAL | M&E Room Temperature |
| Jan 09 | 08:19 | WESTPORTS | N | EASYIO-2.TEMP4 | NORMAL | Server Room Front Temperature |
| Jan 09 | 08:05 | WESTPORTS | N | EASYIO-2.TEMP5 | NORMAL | Server Room Back Temperature |
| Jan 08 | 12:03 | WESTPORTS | N | EASYIO-C.T4-3.UPS... | NORMAL | CT 4-3 - UPS General Alarm |
| Jan 08 | 11:40 | WESTPORTS | N | EASYIO-C.T4-3.TEMP1 | NORMAL | CT4-3 High Temp Alarm |
| Jan 07 | 17:27 | WESTPORTS | N | EASYIO-TB-1.TEMP1 | NORMAL | TB-1 High Temp Alarm |
| Jan 07 | 17:23 | WESTPORTS | N | EASYIO-C.T7-1.TEMP1 | NORMAL | CT7-1 High Temp Alarm |
| Jan 03 | 17:42 | WESTPORTS | N | EASYIO-TB-2.COM... | ALARM | TB-2 Communication Error Alarm |
| Jan 03 | 17:37 | WESTPORTS | N | EASYIO-C.T6-2.UPS... | ALARM | CT 6-2 - UPS General Alarm |
| Jan 03 | 17:36 | WESTPORTS | N | DB_START_FORWA... | NORMAL | The process MAC_PTDL has begun to forward data to SQL Server Native Client 10.0. |
| Jan 03 | 17:36 | WESTPORTS | N | DB_START_FORWA... | NORMAL | The process MAC_DL has begun to forward data to SQL Server Native Client 10.0. |

26 Jan 30 11:30 Toggle Ack View Stack Comments GimView Screen

Exit

Main

Back

Comms Tower

SMS Test

Alarm History

Existing GE Monitoring System: Page 5 view

Question / requirement from Omara Monitoring System:

1. On the main page, how many layout plan can we insert into the system?



Can Omara monitoring system generate more than 1 layout plan?

2. New EMS system to support:
 - a. Web-enable
 - b. SMS system alert notification
 - c. Email system alert notification
 - d. History log (downloadable to record purposes)
3. How can Omara monitoring system integrate with door access system (can share for further details). What is the door access system specification / requirement to integrate with Omara EMS system?
4. Customer expectation: New monitoring system should be better specification and more reliable compare to exiting system.
5. Omara monitoring system interface language need to be in ENGLISH.